

CITY OF FRANKLIN

Ordinance No. 23-04

Industrial Wastewater Ordinance

An Ordinance superseding the City of Franklin Code 13.08 – Industrial Waste Treatment and Ordinance 98-7 – Industrial Wastewater Ordinance for the discharge Of waters into the public sewer system of the City of Franklin, Indiana, and Providing penalties for violations thereof.

BE IT ORDAINED BY THE COMMON COUNCIL OF THE CITY OF FRANKLIN, INDIANA:



TABLE OF CONTENTS

	PAGE
SECTION 1—GENERAL PROVISIONS.	3
.1.1. Purpose and Policy.	3
.1.2. Administration.	4
.1.3. Abbreviations.	4
.1.4. Definitions.	4
SECTION 2—GENERAL SEWER USE REQUIREMENTS.	12
.2.1. Prohibited Discharge Standards.	12
.2.3. National Categorical Pretreatment Standards.	15
.2.4. Local Limits.	15
.2.5. City's Right of Revision.	16
.2.6. Dilution.	16
SECTION 3—PRETREATMENT OF WASTEWATER	17
.3.1. Pretreatment Facilities.	17
.3.2. Additional Pretreatment Measures.	17
.3.3. Accidental Discharge/Slug Discharge Control Plans.	18
.3.4. Hauled Wastewater.	18
SECTION 4—INDIVIDUAL WASTEWATER DISCHARGE PERMITS.	19
.4.1. Wastewater Analysis.	19
.4.2. Individual Wastewater Discharge Permit Requirement	19
.4.3. Individual Wastewater Discharge Permitting: Existing Connections.	19
.4.4. Individual Wastewater Discharge Permitting: New Connections.	19
.4.5. Individual Wastewater Discharge Permit Application Contents.	19
.4.6. Application Signatories and Certifications.	21
.4.7. Individual Wastewater Discharge.	22
SECTION 5—INDIVIDUAL WASTEWATER DISCHARGE PERMIT ISSUANCE.	23
.5.1. Individual Wastewater Discharge Permit Duration.	23
.5.2. Individual Wastewater Discharge Permit Contents.	23
.5.3. Permit Issuance Process.	24
.5.4. Permit Modification.	25
.5.5. Individual Wastewater Discharge Permit Revocation.	25
.5.6. Individual Wastewater Discharge Permit Transfer.	26
.5.7. Individual Wastewater Discharge Permit Reissuance.	26
.5.8. Regulation of Waste Received from Other Jurisdictions.	27
SECTION 6—REPORTING REQUIREMENTS.	29
.6.1. Baseline Monitoring Reports.	29
.6.2. Compliance Schedule Progress Reports.	30
.6.3. Reports on Compliance with Categorical Pretreatment Standard Deadline.	30
.6.4. Periodic Compliance Reports.	31
.6.5. Reports of Changed Conditions.	32
.6.6. Reports of Potential Problems.	33
.6.7. Reports from Unpermitted Users.	33
.6.8. Notice of Violation/Repeat Sampling and Reporting.	34
.6.9. Notification of the Discharge of Hazardous Waste.	34
.6.10. Analytical Requirements.	35

6.11. Sample Collection.		35
6.12.	Date of Receipt of Reports.	36
6.13.	Recordkeeping.	36
SECTION 7—COMPLIANCE MONITORING.		37
7.1. Right of Entry: Inspection and Sampling.		37
If the Superintendent has been refused access to a building, structure, or property, or any part thereof, and is able to demonstrate probable cause to believe that there may be a violation of this ordinance, or that there is a need to inspect and/or sample as part of a routine inspection and sampling program of the City designed to verify compliance with this ordinance or any permit or order issued hereunder, or to protect the overall public health, safety and welfare of the community, the Superintendent may seek issuance of a search warrant from the Johnson County Circuit Court of Franklin, Indiana..		
		37
SECTION 8—CONFIDENTIAL INFORMATION.		38
SECTION 9—PUBLICATION OF USERS IN SIGNIFICANT NONCOMPLIANCE.		39
SECTION 10—ADMINISTRATIVE ENFORCEMENT REMEDIES.		40
10.1 Letter of Violation.		40
10.2.	Consent Orders or Agreed Orders.	40
10.3.	Show Cause Hearing.	40
10.4.	Compliance Orders.	40
10.5.	Cease and Desist Orders.	41
10.6.	Administrative Fines.	41
10.7.	Emergency Suspensions.	41
10.8.	Termination of Discharge.	42
SECTION 11—JUDICIAL ENFORCEMENT REMEDIES.		43
11.1.	Injunctive Relief.	43
11.2.	Civil Penalties.	43
11.3.	Remedies Nonexclusive.	43
SECTION 12—AFFIRMATIVE DEFENSES TO DISCHARGE VIOLATIONS.		44
12.1.	Upset.	44
12.2.	Prohibited Discharge Standards.	45
12.3.	Bypass.	45
SECTION 13—MISCELLANEOUS PROVISIONS.		47
13.1.	Pretreatment Charges and Fees.	47
13.2.	Severability.	47
SECTION 14—EFFECTIVE DATE.		48

ORDINANCE NO. XXXX

SECTION 1—GENERAL PROVISIONS

1.1 Purpose and Policy

This ordinance sets forth uniform requirements for Users of the Publicly Owned Treatment Works for the City of Franklin (“City” or “Franklin”) and enables the City to comply with all applicable State and Federal laws, including the Clean Water Act (33 United States Code [U.S.C.] section 1251 et seq.) and the General Pretreatment Regulations (Title 40 of the *Code of Federal Regulations* [CFR] Part 403). The objectives of this ordinance are:

- A. To prevent the introduction of pollutants into the Publicly Owned Treatment Works that will interfere with its operation;
- B. To prevent the introduction of pollutants into the Publicly Owned Treatment Works that will pass through the Publicly Owned Treatment Works, inadequately treated, into receiving waters, or otherwise be incompatible with the Publicly Owned Treatment Works;
- C. To protect both Publicly Owned Treatment Works personnel who may be affected by wastewater and sludge in the course of their employment and the general public;
- D. To promote reuse and recycling of industrial wastewater and sludge from the Publicly Owned Treatment Works;
- E. To provide for fees for the equitable distribution of the cost of operation, maintenance, and improvement of the Publicly Owned Treatment Works; and
- F. To enable the City to comply with its National Pollutant Discharge Elimination System permit conditions, sludge use and disposal requirements, and any other Federal or State laws to which the Publicly Owned Treatment Works is subject.

This ordinance shall apply to all Users of the Publicly Owned Treatment Works. The ordinance authorizes the issuance of individual wastewater discharge permits; provides for monitoring, compliance, and enforcement activities; establishes administrative review procedures; requires User reporting; and provides for the setting of fees for the equitable distribution of costs resulting from the program established herein.

Unless otherwise defined herein, terms shall have the meanings adopted in the latest edition of *Standard Methods for the Examination of Water and Wastewater*, published by the American Public Health Association, American Waterworks Association, and the Water Pollution Control Federation, as set forth in 40 CFR Part 136. Waste constituents and characteristics shall be measured by standard methods unless a mutually agreed upon acceptable alternative method is adopted by agreement of the permittee and the permitting authority or any other method is established by Federal or State regulatory agencies. Monitoring and metering shall be carried out by customarily accepted methods.

1.2 Administration

Except as otherwise provided herein, the Superintendent shall administer, implement, and enforce the provisions of this ordinance. Any powers granted to or duties imposed upon the Superintendent may be delegated by the Superintendent to a duly authorized City employee.

1.3 Abbreviations

The following abbreviations, when used in this ordinance, shall have the designated meanings:

BOD₅ – Biochemical Oxygen Demand
BMP – Best Management Practice
BMR – Baseline Monitoring Report
CFR – *Code of Federal Regulations*
CIU – Categorical Industrial User
CBOD – Carbonaceous Biological Oxygen Demand
COD – Chemical Oxygen Demand
EPA – U.S. Environmental Protection Agency
EPA RV – Environmental Protection Agency Region V
FOG – Fats, Oils, and Grease
gpd – gallons per day
IC - Indiana Code
IAC - Indiana Administrative Code
IDEM – Indiana Department of Environmental Management
IOSHA – Indiana Occupational Safety & Health Act
IWP – Industrial Wastewater Pretreatment Permit
IU – Industrial User
mg/l – milligrams per liter
MSDS – Material Safety Data Sheet
NPDES – National Pollutant Discharge Elimination System
NSCIU – Non-Significant Categorical Industrial User
POTW – Publicly Owned Treatment Works
RCRA – Resource Conservation and Recovery Act
SIU – Significant Industrial User
SNC – Significant Noncompliance
TSS – Total Suspended Solids
U.S.C. – United States Code
WDP – Wastewater Discharge Permit

1.4 Definitions

Unless a provision explicitly states otherwise, the following terms and phrases, as used in this ordinance, shall have the meanings hereinafter designated.

- A. Act or "the Act" - The Federal Water Pollution Control Act, also known as the Clean Water Act, as amended, 33 U.S.C. section 1251 et seq.
- B. Approval Authority - The Indiana Department of Environmental Management, or the City in the event that the City's pretreatment program is approved by US EPA.

C. Authorized or Duly Authorized Representative of the User -

- (1) If the User is a corporation:
 - (a) The president, secretary, treasurer, or a vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or
 - (b) The manager of one or more manufacturing, production, or operating facilities, provided the manager is authorized to make management decisions that govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiate and direct other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; can ensure that the necessary systems are established or actions taken to gather complete and accurate information for individual wastewater discharge permit or requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
 - (2) If the User is a partnership or sole proprietorship: a general partner or proprietor, respectively.
 - (3) If the User is a Federal, State, or local governmental facility: a director or highest official appointed or designated to oversee the operation and performance of the activities of the government facility, or their designee.
 - (4) The individuals described in paragraphs 1 through 3, above, may designate a Duly Authorized Representative if the authorization is in writing, the authorization specifies the individual or position responsible for the overall operation of the facility from which the discharge originates or having overall responsibility for environmental matters for the company, and the written authorization is submitted to the Superintendent.
- D. Biochemical Oxygen Demand or BOD₅ - The quantity of oxygen utilized in the biochemical oxidation of organic matter under standard laboratory procedures for five (5) days at 20 degrees centigrade, usually expressed as a concentration (e.g., mg/l).
- E. Best Management Practices or BMPs - means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to implement the prohibitions listed in Section 2.1 A and B [40 CFR 403.5(a)(1) and (b)]. BMPs include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw materials storage.

- F. Categorical Pretreatment Standard or Categorical Standard - Any regulation containing pollutant discharge limits promulgated by EPA in accordance with sections 307(b) and (c) of the Act (33 U.S.C. section 1317) that apply to a specific category of Users and that appear in 40 CFR Chapter I, Subchapter N, Parts 405-471.
- G. Categorical Industrial User - An Industrial User subject to a categorical Pretreatment Standard or categorical Standard.
- H. Carbonaceous Biochemical Oxygen Demand (CBOD) – A measure of oxygen that will be consumed by the decomposition of organic matter in water.
- I. Chemical Oxygen Demand or COD - A measure of the oxygen required to oxidize all compounds, both organic and inorganic, in water.
- J. Control Authority – the commissioner of the Indiana Department of Environmental Management.
- K. Daily Maximum - The arithmetic average of all effluent samples for a pollutant collected during a calendar day.
- L. Daily Maximum Limit - The maximum allowable discharge limit of a pollutant during a calendar day. Where Daily Maximum Limits are expressed in units of mass, the daily discharge is the total mass discharged over the course of the day. Where Daily Maximum Limits are expressed in terms of a concentration, the daily discharge is the arithmetic average measurement of the pollutant concentration derived from all measurements taken that day.
- M. Environmental Protection Agency or EPA - The U.S. Environmental Protection Agency or, where appropriate, the Regional Water Management Division Director, the Regional Administrator, or other duly authorized official of said agency.
- N. Existing Source - Any source of discharge that is not a “New Source.”
- O. Grab Sample - A sample that is taken from a wastestream without regard to the flow in the wastestream and over a period of time not to exceed fifteen (15) minutes.
- P. Indirect Discharge or Discharge - The introduction of pollutants into the POTW from any nondomestic source.
- Q. Instantaneous Limit - The maximum concentration of a pollutant allowed to be discharged at any time, determined from the analysis of any discrete or composited sample collected, independent of the industrial flow rate and the duration of the sampling event.
- R. Interference - A discharge that, alone or in conjunction with a discharge or discharges from other sources, inhibits or disrupts the POTW, its treatment processes or operations or its sludge processes, use or disposal; and therefore, is a cause of a violation of Franklin’s NPDES permit or of the prevention of sewage sludge use or disposal in compliance with any of the following statutory/regulatory provisions or permits issued thereunder, or any more stringent State or local

regulations: section 405 of the Act; the Solid Waste Disposal Act, including Title II commonly referred to as the Resource Conservation and Recovery Act (RCRA); any State regulations contained in any State sludge management plan prepared pursuant to Subtitle D of the Solid Waste Disposal Act; the Clean Air Act; and the Toxic Substances Control Act.

- S. Local Limit - Specific discharge limits developed and enforced by [the City] upon industrial or commercial facilities to implement the general and specific discharge prohibitions listed in 40 CFR 403.5(a)(1) and (b).
- T. Medical Waste - Isolation wastes, infectious agents, human blood and blood products, pathological wastes, sharps, body parts, contaminated bedding, surgical wastes, potentially contaminated laboratory wastes, and dialysis wastes.
- U. Monthly Average - The sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month.
- V. Monthly Average Limit - The highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month.
- W. New Source
 - (1) Any building, structure, facility, or installation from which there is (or may be) a discharge of pollutants, the construction of which commenced after the publication of proposed Pretreatment Standards under section 307(c) of the Act that will be applicable to such source if such Standards are thereafter promulgated in accordance with that section, provided that:
 - (a) The building, structure, facility, or installation is constructed at a site at which no other source is located; or
 - (b) The building, structure, facility, or installation totally replaces the process or production equipment that causes the discharge of pollutants at an Existing Source; or
 - (c) The production or wastewater generating processes of the building, structure, facility, or installation are substantially independent of an Existing Source at the same site. In determining whether these are substantially independent, factors such as the extent to which the new facility is integrated with the existing plant, and the extent to which the new facility is engaged in the same general type of activity as the Existing Source, should be considered.
 - (2) Construction on a site at which an Existing Source is located results in a modification rather than a New Source if the construction does not create a new building, structure, facility, or installation meeting the criteria of Section (1)(b) or (c) above but otherwise alters, replaces, or adds to existing process or production equipment.

- (3) Construction of a New Source as defined under this paragraph has commenced if the owner or operator has:
- (a) Begun, or caused to begin, as part of a continuous onsite construction program
 - (i) any placement, assembly, or installation of facilities or equipment; or
 - (ii) significant site preparation work including clearing, excavation, or removal of existing buildings, structures, or facilities which is necessary for the placement, assembly, or installation of new source facilities or equipment; or
 - (b) Entered into a binding contractual obligation for the purchase of facilities or equipment which are intended to be used in its operation within a reasonable time. Options to purchase or contracts which can be terminated or modified without substantial loss, and contracts for feasibility, engineering, and design studies do not constitute a contractual obligation under this paragraph.
- W. Noncontact Cooling Water - Water used for cooling that does not come into direct contact with any raw material, intermediate product, waste product, or finished product.
- X. Pass Through - A discharge proceeding through a POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the City's NPDES permit, including an increase in the magnitude or duration of a violation.
- Y. Person - Any individual, partnership, copartnership, firm, company, corporation, association, joint stock company, trust, estate, governmental entity, or any other legal entity; or their legal representatives, agents, or assigns. This definition includes all Federal, State, and local governmental entities.
- Z. pH - A measure of the acidity or alkalinity of a solution, expressed in standard units.
- AA. Phosphorus - a solid, nonmetallic element whose compounds are used in phosphate fertilizers and whose discharge from WWTP can result in harmful algal blooms which can negatively impact environmental and human health.
- BB. Pollutant - Dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, sewage sludge, munitions, Medical Wastes, chemical wastes, biological materials, radioactive materials, heat, wrecked or discarded equipment, rock, sand, cellar dirt, municipal, agricultural and industrial wastes, and certain characteristics of wastewater (e.g., pH, temperature, TSS, turbidity, color, BOD, CBOD, COD, toxicity, or odor).
- CC. Pretreatment - The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to, or in lieu of, introducing such pollutants into the POTW. This reduction or alteration

can be obtained by physical, chemical, or biological processes; by process changes; or by other means, except by diluting the concentration of the pollutants unless allowed by an applicable Pretreatment Standard.

- DD. Pretreatment Requirements - Any substantive or procedural requirement related to pretreatment imposed on a User, other than a Pretreatment Standard.
- EE. Pretreatment Standards or Standards - Pretreatment Standards shall mean prohibited discharge standards, categorical Pretreatment Standards, and Local Limits per 40 CFR Section 403.3(1).
- FF. Prohibited Discharge Standards or Prohibited Discharges - Absolute prohibitions against the discharge of certain substances; these prohibitions appear in Section 2.1 of this ordinance.
- GG. Publicly Owned Treatment Works or POTW - A treatment works, as defined by section 212 of the Act (33 U.S.C. section 1292), which is owned by the City. This definition includes any devices or systems used in the collection, storage, treatment, recycling, and reclamation of sewage or industrial wastes of a liquid nature and any conveyances, which convey wastewater to a treatment plant.
- HH. Septic Tank Waste - Any sewage from holding tanks such as vessels, chemical toilets, campers, trailers, and septic tanks.
- II. Sewage - Human excrement and gray water (household showers, dishwashing operations, etc.).
- JJ. Significant Industrial User (SIU)
 - (1) An Industrial User subject to categorical Pretreatment Standards under 327 IAC 5-18-10; or
 - (2) An Industrial User that:
 - (a) Discharges an average of twenty-five thousand (25,000) gpd or more of process wastewater to the POTW (excluding sanitary, noncontact cooling and boiler blowdown wastewater);
 - (b) Contributes a process wastestream which makes up five (5) percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or
 - (c) Is designated as such by the control authority on the basis that it has a reasonable potential for adversely affecting the POTW's operation or for violating any Pretreatment Standard or Requirement of 327 IAC 15-19-3.
 - (4) The control authority may, on its own initiative or in response to a petition received from an industrial user or a POTW and in accordance with 327 IAC 5-19-3(6), determine that an industrial user is not a significant industrial user if it does not meet 1.4.II(2)(c) above.

KK. Significant Noncompliance - Shall be applicable to all Significant Industrial Users and shall mean:

- (1) Chronic violations of wastewater discharge limits, defined here as those in which sixty-six percent (66%) or more of all the measurements taken for the same pollutant parameter taken during a six- (6-) month period exceed (by any magnitude) a numeric Pretreatment Standard or Requirement, including Instantaneous Limits as defined in Section 2;
- (2) Technical Review Criteria (TRC) violations, defined here as those in which thirty-three percent (33%) or more of wastewater measurements taken for each pollutant parameter during a six- (6-) month period equals or exceeds the product of the numeric Pretreatment Standard or Requirement including Instantaneous Limits, as defined by Section 2 multiplied by the applicable criteria (1.4 for BOD, TSS, fats, oils and grease, and 1.2 for all other pollutants except pH);
- (3) Any other violation of a Pretreatment Standard or Requirement as defined by Section 2 (Daily Maximum, long-term average, Instantaneous Limit, or narrative standard) that the Superintendent determines has caused, alone or in combination with other discharges, Interference or Pass Through, including endangering the health of POTW personnel or the general public;
- (4) Any discharge of a pollutant that has caused imminent endangerment to the public or to the environment, or has resulted in the Superintendent's exercise of its emergency authority to halt or prevent such a discharge;
- (5) Failure to meet, within ninety (90) days of the scheduled date, a compliance schedule milestone contained in an individual wastewater discharge permit or enforcement order for starting construction, completing construction, or attaining final compliance;
- (6) Failure to provide within forty-five (45) days after the due date, any required reports, including baseline monitoring reports, reports on compliance with categorical Pretreatment Standard deadlines, periodic self-monitoring reports, and reports on compliance with compliance schedules;
- (7) Failure to accurately report noncompliance; or
- (8) Any other violation(s), which may include a violation of Best Management Practices, which the Superintendent determines will adversely affect the operation or implementation of the local pretreatment program.

LL. Slug Load or Slug Discharge - Any discharge at a flow rate or concentration, which could cause a violation of the prohibited discharge standards in Section 2.1 of this ordinance. A Slug Discharge is any Discharge of a non-routine, episodic nature, including but not limited to an accidental spill or a non-customary batch Discharge,

which has a reasonable potential to cause Interference or Pass Through, or in any other way violate the POTW's regulations, Local Limits or Permit conditions.

- MM. Storm Water - Any flow occurring during or following any form of natural precipitation, and resulting from such precipitation, including snowmelt.
- NN. Superintendent - The person designated by the City to supervise the operation of the POTW, and who is charged with certain duties and responsibilities by this ordinance. The term also means a Duly Authorized Representative of the Superintendent.
- OO. Total Suspended Solids or Suspended Solids - The total suspended matter that floats on the surface of, or is suspended in, water, wastewater, or other liquid, and that is removable by laboratory filtering.
- PP. User or Industrial User - A source of indirect discharge.
- QQ. Wastewater - Liquid and water-carried industrial wastes and sewage from residential dwellings, commercial buildings, industrial and manufacturing facilities, and institutions, whether treated or untreated, which are contributed to the POTW.
- RR. Wastewater Treatment Plant or Treatment Plant - That portion of the POTW which is designed to provide treatment of municipal sewage and industrial waste.

SECTION 2—GENERAL SEWER USE REQUIREMENTS

2.1 Prohibited Discharge Standards

- A. General Prohibitions. No User shall introduce or cause to be introduced into the POTW any pollutant or wastewater which causes Pass Through or Interference. These general prohibitions apply to all Users of the POTW whether or not they are subject to categorical Pretreatment Standards or any other National, State, or local Pretreatment Standards or Requirements.
- B. Specific Prohibitions. No User shall introduce or cause to be introduced into the POTW the following pollutants, substances, or wastewater:
- (1) Pollutants which create a fire or explosive hazard in the POTW, including, but not limited to, wastestreams with a closed-cup flashpoint of less than 140 degrees F (60 degrees C) using the test methods specified in 40 CFR 261.21;
 - (2) Pollutants that could cause corrosive structural damage to the POTW, including a discharge with pH lower than five (5.0) or more than ten (10.0);
 - (3) Solid or viscous substances in amounts which will cause obstruction of the flow in the POTW resulting in Interference;
 - (4) Pollutants, including oxygen-demanding pollutants (BOD, etc.), released in a discharge at a flow rate and/or pollutant concentration which, either singly or by interaction with other pollutants, will cause Interference with the POTW;
 - (5) Wastewater having a temperature greater than 150 degrees F or 65 degrees C, or which will inhibit biological activity in the treatment plant resulting in Interference, but in no case wastewater which causes the temperature at the introduction into the treatment plant to exceed 104 degrees F (40 degrees C);
 - (6) Petroleum oil, nonbiodegradable cutting oil, products of mineral oil origin, or fats, oils, or greases of animal or vegetable origin in amounts that will cause Interference or Pass Through;
 - (7) Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;
 - (8) Trucked or hauled pollutants, except at discharge points designated by the Superintendent in accordance with Section 3.4 of this ordinance;
 - (9) Noxious or malodorous liquids, gases, solids, or other wastewater which, either singly or by interaction with other wastes, are sufficient to create a public nuisance or a hazard to life, or to prevent entry into the sewers for maintenance or repair;
 - (10) Wastewater which imparts color which cannot be removed by the treatment process, such as, but not limited to, dye wastes and vegetable tanning

solutions, which consequently imparts color to the treatment plant's effluent, thereby violating the City's NPDES permit;

- (11) Wastewater containing any radioactive wastes or isotopes except in compliance with applicable State or Federal regulations;
- (12) Storm Water, surface water, ground water, artesian well water, roof runoff, subsurface drainage, swimming pool drainage, condensate, deionized water, Noncontact Cooling Water, and unpolluted wastewater, unless specifically authorized by the Superintendent;
- (13) Sludges, screenings, or other residues from the pretreatment of industrial wastes;
- (14) Medical Wastes, except as specifically authorized by the Superintendent in an individual wastewater discharge permit or a general permit;
- (15) Wastewater causing, alone or in conjunction with other sources, the treatment plant's effluent to fail toxicity test;
- (16) Detergents, surface-active agents, or other substances which that might cause excessive foaming in the POTW;
- (17) Wastewater causing two readings on an explosion hazard meter at the point of discharge into the POTW, or at any point in the POTW, of more than ten percent (10 %).

Pollutants, substances, or wastewater prohibited by this Section shall not be processed or stored in such a manner that they could be discharged to the POTW.

2.2 Abnormal Waste Surcharge

- A. In the event the Approving Authority excludes a customer from the requirements of Section 2.1 and the customer discharges abnormal industrial wastes to the public sanitary sewerage system having an average total suspended solids (TSS) content in excess of 250 mg/l, an average of five (5) day BOD in excess of 200 mg/l, and/or an average ammonia-nitrogen content in excess of 30 mg/l, the customer shall pay a surcharge based upon the excess strength of his wastes.
- B. The costs of treatment for each pound of TSS, BOD₅, or ammonia-nitrogen removed by each treatment works may be reviewed by the City at the end of each fiscal year. If a discrepancy exists between the actual costs as found by the City and the estimated costs, the Approving Authority shall increase or decrease the surcharge rates sufficiently to cover only the projected actual costs for the ensuing year.
- C. No reduction in sewerage service charges, fees, or taxes will be permitted because of the fact that certain industrial wastes discharged to the public sanitary sewerage system contain less than 250 milligrams per liter of TSS, 200 milligrams per liter BOD₅, or 30 mg/l of ammonia-nitrogen.

2.3 National Categorical Pretreatment Standards

When applicable, compliance is required with all applicable pretreatment standards and requirements by indirect dischargers. The categorical pretreatment standards found at 40 CFR, Chapter I, Subchapter N, Parts 405-471 are hereby incorporated.

- A. Where a categorical pretreatment standard is expressed only in terms of either the mass or the concentration of a pollutant in wastewater, the Superintendent may impose equivalent concentration or mass limits in accordance with 40 CFR 403.6(c).
- B. When wastewater subject to a categorical pretreatment standard is mixed with wastewater not regulated by the same standard, the Superintendent shall impose an alternate limit using the combined wastestream formula in 40 CFR 403.6(e).
- C. A user may obtain a net gross adjustment to a categorical standard in accordance with 40 CFR 403.15.

State pretreatment standards are located in 327 Indiana Administrative Code Article 5. When applicable, compliance is required with all applicable pretreatment standards and requirements by indirect dischargers

2.4 Local Limits

- A. The Superintendent is authorized to establish Local Limits pursuant to 40 CFR 403.5(c).
- B. The following pollutant limits are established to protect against Pass Through and Interference. No person shall discharge wastewater containing in excess of the following Daily Maximum Limit.

0.29	mg/l Arsenic
0.09	mg/l Cadmium
0.46	mg/l Chromium (Hexavalent)
1.71	mg/l Chromium (Total)
2.07	mg/l Copper
0.23	mg/l Cyanide
1.45	mg/l Lead
0.001	mg/l Mercury
0.60	mg/l Molybdenum
3.74	mg/l Nickel
200	mg/l Oil and/or Grease (animal or vegetable origin)
100	mg/l Oil and/or Grease (mineral or petroleum origin)
0.32	mg/l Selenium
0.83	mg/l Silver
1.00	mg/l Total Phenols
2.00	mg/l Total Toxic Organics (TTO)
4.50	mg/l Zinc

- C. The above limits apply at the point where the wastewater is discharged to the POTW. All concentrations for metallic substances are for total metal unless

indicated otherwise. The Superintendent may impose mass limitations in addition to the concentration-based limitations above.

- D. Under the direction of the Superintendent, Best Management Practice's may be required as part of the Local Limits in Section 2.4 B and may include: treatment requirements; operating procedures and practices to control site runoff, spillage or leaks, sludge or waste disposal; or drainage from raw materials storage.

2.5 City's Right of Revision

The City reserves the right to establish, by ordinance or in individual wastewater discharge permits, more stringent Standards or Requirements on discharges to the POTW consistent with the purpose of this ordinance.

2.6 Dilution

No User shall ever increase the use of process water, or in any way attempt to dilute a discharge, as a partial or complete substitute for adequate treatment to achieve compliance with a discharge limitation unless expressly authorized by an applicable Pretreatment Standard or Requirement. The Superintendent may impose mass limitations on Users who are using dilution to meet applicable Pretreatment Standards or Requirements, or in other cases when the imposition of mass limitations is appropriate.

SECTION 3—PRETREATMENT OF WASTEWATER

3.1 Pretreatment Facilities

Users shall provide wastewater treatment as necessary to comply with this ordinance and shall achieve compliance with all Categorical Pretreatment Standards, Local Limits, and the Prohibited Discharge Standards set out in Section 2 of this ordinance within the time limitations specified by EPA, the State, or the Superintendent, whichever is more stringent. Any facilities necessary for compliance shall be provided, operated, and maintained at the User's expense. Detailed plans describing such facilities and operating procedures shall be submitted to the Superintendent for review and shall be acceptable to the Superintendent before such facilities are constructed. The review of such plans and operating procedures shall in no way relieve the User from the responsibility of modifying such facilities as necessary to produce a discharge acceptable to the City under the provisions of this ordinance.

3.2 Additional Pretreatment Measures

- A. Whenever deemed necessary, the Superintendent may require Users to restrict their discharge during peak flow periods, designate that certain wastewater be discharged only into specific sewers, relocate and/or consolidate points of discharge, separate sewage wastestreams from industrial wastestreams, and such other conditions as may be necessary to protect the POTW and determine the User's compliance with the requirements of this ordinance.
 - B. The Superintendent may require any person discharging into the POTW to install and maintain, on their property and at their expense, a suitable storage and flow-control facility to ensure equalization of flow. An individual wastewater discharge permit may be issued solely for flow equalization.
 - C. Grease, oil, and sand interceptors shall be provided when, in the opinion of the Superintendent, they are necessary for the proper handling of wastewater containing excessive amounts of grease and oil, or sand; except that such interceptors shall not be required for residential users. All interception units shall be of a type and capacity approved by the Superintendent, shall comply with the City's Oil and Grease Management Policy and shall be so located to be easily accessible for cleaning and inspection. Such interceptors shall be inspected, cleaned, and repaired in accordance with the City's Oil and Grease Management Policy by the User at their expense.
- A. Users with the potential to discharge flammable substances may be required to install and maintain an approved combustible gas detection meter.
 - B. Users which operate vehicular wash facilities shall provide, operate, and maintain pretreatment facilities approved by the Superintendent to control the discharge of greases, fats, oils, and food solids to the POTW.
 - C. Users which operate food preparation facilities shall provide, operate, and maintain pretreatment facilities approved by the Superintendent to control the discharge of toxics to the POTW.

3.3 Accidental Discharge/Slug Discharge Control Plans

The Superintendent shall evaluate whether each SIU needs an accidental discharge/slug discharge control plan or other action to control Slug Discharges. The Superintendent may require any User to develop, submit for approval, and implement such a plan or take such other action that may be necessary to control Slug Discharges. Alternatively, the Superintendent may develop such a plan for any User. An accidental discharge/slug discharge control plan shall address, at a minimum, the following:

- A. Description of discharge practices, including nonroutine batch discharges;
- B. Description of stored chemicals;
- C. Procedures for immediately notifying the Superintendent of any accidental or Slug Discharge, as required by Section 6.6 of this ordinance; and
- D. Procedures to prevent adverse impact from any accidental or Slug Discharge. Such procedures include, but are not limited to, inspection and maintenance of storage areas, handling and transfer of materials, loading and unloading operations, control of plant site runoff, worker training, building of containment structures or equipment, measures for containing toxic organic pollutants, including solvents, and/or measures and equipment for emergency response.

3.4 Hauled Wastewater

- A. Septic tank waste may be introduced into the POTW only at locations designated by the Superintendent, and at such times as are established by the Superintendent. Such waste shall not violate Section 2 of this ordinance or any other requirements established by the City. The Superintendent may require septic tank waste haulers to obtain individual wastewater discharge permits.
- B. The Superintendent may require haulers of industrial waste to obtain individual wastewater discharge permits. The Superintendent may require generators of hauled industrial waste to obtain individual wastewater discharge permits. The Superintendent also may prohibit the disposal of hauled industrial waste. The discharge of hauled industrial waste is subject to all other requirements of this ordinance.
- C. Industrial waste haulers may discharge loads only at locations designated by the Superintendent. No load may be discharged without prior consent of the Superintendent. The Superintendent may collect samples of each hauled load to ensure compliance with applicable Standards. The Superintendent may require the industrial waste hauler to provide a waste analysis of any load prior to discharge.
- D. Industrial waste haulers must provide a waste-tracking form for every load. This form shall include, at a minimum, the name and address of the industrial waste hauler, permit number, truck identification, names and addresses of sources of waste, and volume and characteristics of waste. The form shall identify the type of industry, known or suspected waste constituents, and whether any wastes are RCRA hazardous wastes.

SECTION 4—INDIVIDUAL WASTEWATER DISCHARGE PERMITS

4.1 Wastewater Analysis

When requested by the Superintendent, a User must submit information on the nature and characteristics of its wastewater within 30 days of the request. The Superintendent is authorized to prepare a form for this purpose and may periodically require Users to update this information.

4.2 Individual Wastewater Discharge Permit Requirement

- A. No Significant Industrial User shall discharge wastewater into the POTW without first obtaining a wastewater discharge permit from the Control Authority and/or an individual wastewater discharge permit from the Superintendent, except when a Significant Industrial User that has filed a timely application pursuant to Section 4.3 of this ordinance may continue to discharge for the time period specified therein.
- B. The Superintendent may require other Users to obtain individual wastewater discharge permits as necessary to carry out the purposes of this ordinance.
- C. Any violation of the terms and conditions of an individual wastewater discharge permit shall be deemed a violation of this ordinance and subjects the wastewater discharge permittee to the sanctions set out in Sections 10 through 12 of this ordinance. Obtaining an individual wastewater discharge permit does not relieve a permittee of its obligation to comply with all Federal and State Pretreatment Standards or Requirements or with any other requirements of Federal, State, and local law.

4.3 Individual Wastewater Discharge Permitting: Existing Connections

Any User required to obtain an individual wastewater discharge permit who was discharging wastewater into the POTW prior to the effective date of this ordinance and who wishes to continue such discharges in the future, shall, within 30 days after said date, apply to the Superintendent for an individual wastewater discharge permit in accordance with Section 4.5 of this ordinance, and shall not cause or allow discharges to the POTW to continue after 30 days of the effective date of this ordinance except in accordance with an individual wastewater discharge permit issued by the Superintendent.

4.4 Individual Wastewater Discharge Permitting: New Connections

Any User required to obtain an individual wastewater discharge permit who proposes to begin or recommence discharging into the POTW must obtain such permit prior to the beginning or recommencing of such discharge. An application for this individual wastewater discharge permit, in accordance with Section 4.5 of this ordinance, must be filed at least 30 days prior to the date upon which any discharge will begin or recommence.

4.5 Individual Wastewater Discharge Permit Application Contents

- A. All Users required to obtain an individual wastewater discharge permit must submit a permit application. Users that are eligible may request a general permit under

Section 4.6. The Superintendent may require Users to submit all or some of the following information as part of a permit application:

- (1) Identifying Information.
 - (a) The name and address of the facility, including the name of the operator and owner.
 - (b) Contact information, description of activities, facilities, and plant production processes on the premises;
- (2) Environmental Permits. A list of any environmental control permits held by or for the facility.
- (3) Description of Operations.
 - (a) A brief description of the nature, average rate of production (including each product produced by type, amount, processes, and rate of production), and standard industrial classifications of the operation(s) carried out by such User. This description should include a schematic process diagram, which indicates points of discharge to the POTW from the regulated processes.
 - (b) Types of wastes generated, and a list of all raw materials and chemicals used or stored at the facility which are, or could accidentally or intentionally be, discharged to the POTW;
 - (c) Number and type of employees, hours of operation, and proposed or actual hours of operation;
 - (d) Type and amount of raw materials processed (average and maximum per day);
 - (e) Site plans, floor plans, mechanical and plumbing plans, and details to show all sewers, floor drains, and appurtenances by size, location, and elevation, and all points of discharge;
- (4) Time and duration of discharges;
- (5) The location for monitoring all wastes covered by the permit;
- (6) Flow Measurement. Information showing the measured average daily and maximum daily flow, in gallons per day, to the POTW from regulated process streams and other streams, as necessary, to allow use of the combined wastestream formula set out in 40 CFR 403.6(e) and subject to approval by the Superintendent.
- (7) Measurement of Pollutants.

- (a) The categorical Pretreatment Standards applicable to each regulated process and any new categorically regulated processes for Existing Sources.
 - (b) The results of sampling and analysis identifying the nature and concentration, and/or mass, where required by the Standard or by the uperintendent, of regulated pollutants in the discharge from each regulated process.
 - (c) Instantaneous, Daily Maximum, and long-term average concentrations, or mass, where required, shall be reported.
 - (d) The sample shall be representative of daily operations and shall be analyzed in accordance with procedures set out in Section 6.10 of this ordinance. Where the Standard requires compliance with a BMP or pollution prevention alternative, the User shall submit documentation as required by the Superintendent or the applicable Standards to determine compliance with the Standard.
 - (e) Sampling must be performed in accordance with procedures set out in Section 6.11 of this ordinance.
- (8) Any other information as may be deemed necessary by the Superintendent to evaluate the permit application.
- B. Incomplete or inaccurate applications will not be processed and will be returned to the User for revision.

4.6 Application Signatories and Certifications

- A. All wastewater discharge permit applications, User reports and certification statements must be signed by an Authorized Representative of the User and contain the following statement:
- "I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."
- B. If the designation of an Authorized Representative is no longer accurate because a different individual or position has responsibility for the overall operation of the facility or overall responsibility for environmental matters for the company, a new written authorization satisfying the requirements of this Section must be submitted to the Superintendent prior to or together with any reports to be signed by an Authorized Representative.

- C. A facility determined to be a Non-Significant Categorical Industrial User by the Superintendent pursuant to 1.4 GG(3) must annually submit the signed certification statement in Section 4.6A.

4.7 Individual Wastewater Discharge

The Superintendent will evaluate the data furnished by the User and may require additional information. The Superintendent may deny any application for an individual wastewater discharge permit. The Superintendent may also deny or condition new or increased contributions of pollutants, or changes in the nature of pollutants, to the POTW by Industrial Users where such contributions do not meet applicable Pretreatment Standards and Requirements or where such contributions would cause the POTW to violate its NPDES permit.

SECTION 5—INDIVIDUAL WASTEWATER DISCHARGE PERMIT ISSUANCE

5.1 Individual Wastewater Discharge Permit Duration

At the discretion of the Superintendent, an individual wastewater discharge permit may be issued for a specified time period, not to exceed five (5) years from the effective date of the permit. An individual wastewater discharge permit may be issued for a period less than five (5) years, at the discretion of the Superintendent. Each individual wastewater discharge permit will indicate a specific date upon which it will expire.

5.2 Individual Wastewater Discharge Permit Contents

An individual wastewater discharge permit shall include such conditions as are deemed reasonably necessary by the Superintendent to prevent Pass Through or Interference, protect the quality of the water body receiving the treatment plant's effluent, protect worker health and safety, facilitate sludge management and disposal, and protect against damage to the POTW.

- A. Individual wastewater discharge permits must contain:
 - (1) A statement that indicates the wastewater discharge permit issuance date, expiration date and effective date;
 - (2) A statement that the wastewater discharge permit is nontransferable.
 - (3) Effluent limits, including Best Management Practices, based on applicable Pretreatment Standards;
 - (4) Self-monitoring, sampling, reporting, notification and recordkeeping requirements, including an identification of the pollutants to be monitored (including the process for seeking a waiver for a pollutant neither present nor expected to be present in the Discharge in accordance with 40 CFR Section 403.12(e)(2), or a specific waived pollutant in the case of an individual control mechanism), sampling location, sampling frequency, and sample type, based on the applicable categorical Pretreatment Standards, local limits, and State and local law;
 - (5) A statement of applicable civil and criminal penalties for violation of Pretreatment Standards and Requirements, and any applicable compliance schedule. Such schedule may not extend the time for compliance beyond that required by applicable Federal, State, or local law.
 - (6) Requirements to control Slug Discharge, if determined by the Superintendent to be necessary.
- B. Individual wastewater discharge permits may contain, but need not be limited to, the following conditions:
 - (1) Limits on the average and/or maximum rate of discharge, time of discharge, and/or requirements for flow regulation and equalization;

- (2) Requirements for the installation of pretreatment technology, pollution control, or construction of appropriate containment devices, designed to reduce, eliminate, or prevent the introduction of pollutants into the treatment works;
- (3) Requirements for the development and implementation of spill control plans or other special conditions including management practices necessary to adequately prevent accidental, unanticipated, or nonroutine discharges;
- (4) Development and implementation of waste minimization plans to reduce the amount of pollutants discharged to the POTW;
- (5) The unit charge or schedule of User charges and fees for the management of the wastewater discharged to the POTW;
- (6) Requirements for installation and maintenance of inspection and sampling facilities and equipment, including flow measurement devices;
- (7) A statement that compliance with the individual wastewater discharge permit does not relieve the permittee of responsibility for compliance with all applicable Federal and State Pretreatment Standards, including those which become effective during the term of the individual wastewater discharge permit; and
- (8) Other conditions as deemed appropriate by the Superintendent to ensure compliance with this ordinance, and State and Federal laws, rules, and regulations.

5.3 Permit Issuance Process

- A. Permit Appeals. The Superintendent shall provide public notice of the issuance of an individual wastewater discharge permit. Any person, including the User, may petition the Superintendent to reconsider the terms of an individual wastewater discharge permit within thirty (30) days of notice of its issuance.
 - (1) Failure to submit a timely petition for review shall be deemed to be a waiver of the administrative appeal.
 - (2) In its petition, the appealing party must indicate the individual wastewater discharge permit provisions objected to, the reasons for this objection, and the alternative condition, if any, it seeks to place in the individual wastewater discharge permit.
 - (3) The effectiveness of the individual wastewater discharge permit shall not be stayed pending the appeal.
 - (4) If the Superintendent fails to act within thirty (30) days, a request for reconsideration shall be deemed to be denied. Decisions not to reconsider an individual wastewater discharge permit, not to issue an individual wastewater discharge permit, or not to modify an individual wastewater discharge permit shall be considered final administrative actions for purposes of judicial review.

- (5) Aggrieved parties seeking judicial review of the final administrative individual wastewater discharge permit decision must do so by filing a complaint with the Johnson County Circuit Court within thirty (30) days of the final administrative wastewater discharge permit decision.

5.4 Permit Modification

- A. The Superintendent may modify an individual wastewater discharge permit for good cause, including, but not limited to, the following reasons:
 - (1) To incorporate any new or revised Federal, State, or local Pretreatment Standards or Requirements;
 - (2) To address significant alterations or additions to the User's operation, processes, or wastewater volume or character since the time of the individual wastewater discharge permit issuance;
 - (3) A change in the POTW that requires either a temporary or permanent reduction or elimination of the authorized discharge;
 - (4) Information indicating that the permitted discharge poses a threat to the City's POTW, City personnel, or the receiving waters;
 - (5) Violation of any terms or conditions of the individual wastewater discharge permit;
 - (6) Misrepresentations or failure to fully disclose all relevant facts in the wastewater discharge permit application or in any required reporting;
 - (7) Revision of or a grant of variance from categorical Pretreatment Standards pursuant to 40 CFR 403.13;
 - (8) To correct typographical or other errors in the individual wastewater discharge permit; or
 - (9) To reflect a transfer of the facility ownership or operation to a new owner or operator where requested in accordance with Section 5.6.

5.5 Individual Wastewater Discharge Permit Revocation

The Superintendent may revoke an individual wastewater discharge permit for good cause, including, but not limited to, the following reasons:

- A. Failure to notify the Superintendent of significant changes to the wastewater prior to the changed discharge;
- B. Failure to provide prior notification to the Superintendent of changed conditions pursuant of this ordinance;
- C. Misrepresentation or failure to fully disclose all relevant facts in the wastewater discharge permit application;

- D. Falsifying self-monitoring reports and certification statements;
- E. Tampering with monitoring equipment;
- F. Refusing to allow the Superintendent timely access to the facility premises and records;
- G. Failure to meet effluent limitations;
- H. Failure to pay fines;
- I. Failure to pay sewer charges;
- J. Failure to meet compliance schedules;
- K. Failure to complete a wastewater survey or the wastewater discharge permit application;
- L. Failure to provide advance notice of the transfer of business ownership of a permitted facility; or
- M. Violation of any Pretreatment Standard or Requirement, or any terms of the wastewater discharge permit or this ordinance.

Individual wastewater discharge permits shall be voidable upon cessation of operations or transfer of business ownership. All individual wastewater discharge permits issued to a User are void upon the issuance of a new individual wastewater discharge permit to that User.

5.6 Individual Wastewater Discharge Permit Transfer

Individual wastewater discharge permits may be transferred to a new owner or operator only if the permittee gives at least 60 days advance notice to the Superintendent and the Superintendent approves the individual wastewater discharge permit transfer. The notice to the Superintendent must include a written certification by the new owner or operator which:

- A. States that the new owner and/or operator has no immediate intent to change the facility's operations and processes;
- B. Identifies the specific date on which the transfer is to occur; and
- C. Acknowledges full responsibility for complying with the existing individual wastewater discharge permit.

Failure to provide advance notice of a transfer renders the individual wastewater discharge permit void as of the date of facility transfer.

5.7 Individual Wastewater Discharge Permit Reissuance

A User with an expiring individual wastewater discharge permit shall apply for individual wastewater discharge permit reissuance by submitting a complete permit application, in

accordance with Section 4.5 of this ordinance, a minimum of one hundred eighty (180) days prior to the expiration of the User's existing individual wastewater discharge permit.

5.8 Regulation of Waste Received from Other Jurisdictions

- A. If another municipality, or User located within another municipality, contributes wastewater to the POTW, the Superintendent shall enter into an intermunicipal agreement with the contributing municipality.
- B. Prior to entering into an agreement required by paragraph A, above, the Superintendent shall request the following information from the contributing municipality:
 - (1) A description of the quality and volume of wastewater discharged to the POTW by the contributing municipality;
 - (2) An inventory of all Users located within the contributing municipality that are discharging to the POTW; and
 - (3) Such other information as the Superintendent may deem necessary.
- C. An intermunicipal agreement, as required by paragraph A, above, shall contain the following conditions:
 - (1) A requirement for the contributing municipality to adopt a sewer use ordinance which is at least as stringent as this ordinance and Local Limits, including required Baseline Monitoring Reports (BMRs) which are at least as stringent as those set out in Section 2.4 of this ordinance. The requirement shall specify that such ordinance and limits must be revised as necessary to reflect changes made to the City's ordinance or Local Limits;
 - (2) A requirement for the contributing municipality to submit a revised User inventory on at least an annual basis;
 - (3) A provision specifying which pretreatment implementation activities, including individual wastewater discharge permit issuance, inspection and sampling, and enforcement, will be conducted by the contributing municipality; which of these activities will be conducted by the Superintendent; and which of these activities will be conducted jointly by the contributing municipality and the Superintendent;
 - (4) A requirement for the contributing municipality to provide the Superintendent with access to all information that the contributing municipality obtains as part of its pretreatment activities;
 - (5) Limits on the nature, quality, and volume of the contributing municipality's wastewater at the point where it discharges to the POTW;
 - (6) Requirements for monitoring the contributing municipality's discharge;

- (7) A provision ensuring the Superintendent access to the facilities of Users located within the contributing municipality's jurisdictional boundaries for the purpose of inspection, sampling, and any other duties deemed necessary by the Superintendent; and
- (8) A provision specifying remedies available for breach of the terms of the intermunicipal agreement.

SECTION 6—REPORTING REQUIREMENTS

6.1 Baseline Monitoring Reports

- A. Within either one hundred eighty (180) days after the effective date of a categorical Pretreatment Standard, or the final administrative decision on a category determination under 40 CFR 403.6(a)(4), whichever is later, existing Categorical Industrial Users currently discharging to or scheduled to discharge to the POTW shall submit to the Superintendent a report which contains the information listed in paragraph B, below. At least ninety (90) days prior to commencement of their discharge, New Sources, and sources that become Categorical Industrial Users subsequent to the promulgation of an applicable categorical Standard, shall submit to the Superintendent a report which contains the information listed in paragraph B, below. A New Source shall report the method of pretreatment it intends to use to meet applicable categorical Standards. A New Source also shall give estimates of its anticipated flow and quantity of pollutants to be discharged.
- B. Users described above shall submit the information set forth below.
- (1) All information required in Section 4.5A (1) (a), Section 4.5A (2), Section 4.5A (3) (a), and Section 4.5A (6).
 - (2) Measurement of pollutants.
 - (a) The User shall provide the information required in Section 4.5 A (7) (a) through (d).
 - (b) The User shall take a minimum of one representative sample to compile that data necessary to comply with the requirements of this paragraph.
 - (c) Samples should be taken immediately downstream from pretreatment facilities if such exist or immediately downstream from the regulated process if no pretreatment exists. If other wastewaters are mixed with the regulated wastewater prior to pretreatment the User should measure the flows and concentrations necessary to allow use of the combined wastestream formula in 40 CFR 403.6(e) to evaluate compliance with the Pretreatment Standards. Where an alternate concentration or mass limit has been calculated in accordance with 40 CFR 403.6(e) this adjusted limit along with supporting data shall be submitted to the Control Authority;
 - (d) Sampling and analysis shall be performed in accordance with Section 6.10 and 6.11;
 - (e) The Superintendent may allow the submission of a baseline report which utilizes only historical data so long as the data provides information sufficient to determine the need for industrial pretreatment measures;
 - (f) The baseline report shall indicate the time, date and place of sampling and methods of analysis, and shall certify that such sampling and

analysis is representative of normal work cycles and expected pollutant Discharges to the POTW.

- (3) **Compliance Certification.** A statement, reviewed by the User's Authorized Representative as defined in Section 1.4 C and certified by a qualified professional, indicating whether Pretreatment Standards are being met on a consistent basis, and, if not, whether additional operation and maintenance (O&M) and/or additional pretreatment is required to meet the Pretreatment Standards and Requirements.
- (4) **Compliance Schedule.** If additional pretreatment and/or O&M will be required to meet the Pretreatment Standards, the shortest schedule by which the User will provide such additional pretreatment and/or O&M must be provided. The completion date in this schedule shall not be later than the compliance date established for the applicable Pretreatment Standard. A compliance schedule pursuant to this Section must meet the requirements set out in Section 6.2 of this ordinance.
- (5) **Signature and Report Certification.** All baseline monitoring reports must be certified in accordance with Section 4.6 of this ordinance and signed by an Authorized Representative as defined in Section 1.4C.

6.2 Compliance Schedule Progress Reports

The following conditions shall apply to the compliance schedule required by Section 6.1(B)(4) of this ordinance:

- A. The schedule shall contain progress increments in the form of dates for the commencement and completion of major events leading to the construction and operation of additional pretreatment required for the User to meet the applicable Pretreatment Standards (such events include, but are not limited to, hiring an engineer, completing preliminary and final plans, executing contracts for major components, commencing and completing construction, and beginning and conducting routine operation);
- B. No increment referred to above shall exceed nine (9) months;
- C. The User shall submit a progress report to the Superintendent no later than fourteen (14) days following each date in the schedule and the final date of compliance including, as a minimum, whether or not it complied with the increment of progress, the reason for any delay, and, if appropriate, the steps being taken by the User to return to the established schedule; and
- D. In no event shall more than nine (9) months elapse between such progress reports to the Superintendent.

6.3 Reports on Compliance with Categorical Pretreatment Standard Deadline

Within ninety (90) days following the date for final compliance with applicable categorical Pretreatment Standards, or in the case of a New Source following commencement of the introduction of wastewater into the POTW, any User subject to such Pretreatment Standards

and Requirements shall submit to the Superintendent a report containing the information described in Section 4.5A(6) and (7) and 6.1(B)(2) of this ordinance. For all other Users subject to categorical Pretreatment Standards expressed in terms of allowable pollutant discharge per unit of production (or other measure of operation), this report shall include the User's actual production during the appropriate sampling period. All compliance reports must be signed and certified in accordance with Section 4.6 A of this ordinance. All sampling will be done in conformance with Section 6.11.

6.4 Periodic Compliance Reports

- A. All Significant Industrial Users must, at a frequency determined by the Superintendent submit no less than twice per year June and December reports indicating the nature, concentration of pollutants in the discharge which are limited by Pretreatment Standards and the measured or estimated average and maximum daily flows for the reporting period. In cases where the Pretreatment Standard requires compliance with a Best Management Practice (BMP) or pollution prevention alternative, the User must submit documentation required by the Superintendent or the Pretreatment Standard necessary to determine the compliance status of the User.
- B. All wastewater samples must be representative of the User's discharge. Wastewater monitoring and flow measurement facilities shall be properly operated, kept clean, and maintained in good working order at all times. The failure of a User to keep its monitoring facility in good working order shall not be grounds for the User to claim that sample results are unrepresentative of its discharge.
- C. If a User subject to the reporting requirement in this section monitors any regulated pollutant at the appropriate sampling location more frequently than required by the Superintendent, using the procedures prescribed in Section 6.11 of this ordinance, the results of this monitoring shall be included in the report.
- D. The City may authorize an Industrial User subject to a categorical Pretreatment Standard to forego sampling of a pollutant regulated by a categorical Pretreatment Standard if the Industrial User has demonstrated through sampling and other technical factors that the pollutant is neither present nor expected to be present in the Discharge, or is present only at background levels from intake water and without any increase in the pollutant due to activities of the Industrial User. [see 40 CFR 403.12(e)(2)] This authorization is subject to the following conditions:
 - (1) The waiver may be authorized where a pollutant is determined to be present solely due to sanitary wastewater discharged from the facility provided that the sanitary wastewater is not regulated by an applicable categorical Standard and otherwise includes no process wastewater.
 - (2) The monitoring waiver is valid only for the duration of the effective period of the individual wastewater discharge permit, but in no case longer than 5 years. The User must submit a new request for the waiver before the waiver can be granted for each subsequent individual wastewater discharge permit.
 - (3) In making a demonstration that a pollutant is not present, the Industrial User must provide data from at least one sampling of the facility's process

wastewater prior to any treatment present at the facility that is representative of all wastewater from all processes.

- (4) The request for a monitoring waiver must be signed in accordance with Section 1.4C, and include the certification statement in 6.14 A (40 CFR 403.6(a)(2)(ii)).
 - (5) Non-detectable sample results may be used only as a demonstration that a pollutant is not present if the EPA approved method from 40 CFR Part 136 with the lowest minimum detection level for that pollutant was used in the analysis.
 - (6) Any grant of the monitoring waiver by the [Superintendent] must be included as a condition in the User's permit. The reasons supporting the waiver and any information submitted by the User in its request for the waiver must be maintained by the [Superintendent] for 3 years after expiration of the waiver.
 - (7) Upon approval of the monitoring waiver and revision of the User's permit by the Superintendent, the Industrial User must certify on each report with the statement in Section 6.11 C below, that there has been no increase in the pollutant in its wastestream due to activities of the Industrial User.
 - (8) In the event that a waived pollutant is found to be present or is expected to be present because of changes that occur in the User's operations, the User must immediately: Comply with the monitoring requirements of Section 6.4 A, or other more frequent monitoring requirements imposed by the Superintendent, and notify the Superintendent.
 - (9) This provision does not supersede certification processes and requirements established in categorical Pretreatment Standards, except as otherwise specified in the categorical Pretreatment Standard.
- E. The Control Authority must require appropriate reporting from those Industrial Users with Discharges that are not subject to categorical Pretreatment Standards. Significant Non-categorical Industrial Users must submit to the Control Authority at least once every six months (on dates specified by the Control Authority) a description of the nature, concentration, and flow of the pollutants required to be reported by the Control Authority. In cases where a local limit requires compliance with a Best Management Practice or pollution prevention alternative, the User must submit documentation required by the Control Authority to determine the compliance status of the User. These reports must be based on sampling and analysis performed in the period covered by the report, and in accordance with the techniques described in part 136 and amendments thereto. This sampling and analysis may be performed by the Control Authority in lieu of the significant non-categorical Industrial User.

6.5 Reports of Changed Conditions

Each User must notify the Superintendent of any significant changes to the User's operations or system which might alter the nature, quality, or volume of its wastewater at least ninety (90) days before the change.

- A. The Superintendent may require the User to submit such information as may be deemed necessary to evaluate the changed condition, including the submission of a wastewater discharge permit application under Section 4.5 of this ordinance.
- B. The Superintendent may issue an individual wastewater discharge permit under Section 5.3 of this ordinance or modify an existing wastewater discharge permit under Section 5.4 of this ordinance in response to changed conditions or anticipated changed conditions.
- C. For purposes of this requirement, significant changes include, but are not limited to, flow increases of twenty percent (20%) or greater and the discharge of any previously unreported pollutants.

6.6 Reports of Potential Problems

- A. In the case of any discharge, including, but not limited to, accidental discharges, discharges of a nonroutine, episodic nature, a noncustomary batch discharge, a Slug Discharge or Slug Load, that might cause potential problems for the POTW, the User shall immediately telephone and notify the Superintendent of the incident. This notification shall include the location of the discharge, type of waste, concentration and volume, if known, and corrective actions taken by the User.
- B. Within five (5) days following such discharge, the User shall, unless waived by the Superintendent, submit a detailed written report describing the cause(s) of the discharge and the measures to be taken by the User to prevent similar future occurrences. Such notification shall not relieve the User of any expense, loss, damage, or other liability which might be incurred as a result of damage to the POTW, natural resources, or any other damage to person or property; nor shall such notification relieve the User of any fines, penalties, or other liability which may be imposed pursuant to this ordinance.
- C. A notice shall be permanently posted on the User's bulletin board or other prominent place advising employees who to call in the event of a discharge described in paragraph A, above. Employers shall ensure that all employees, who could cause such a discharge to occur, are advised of the emergency notification procedure.
- D. Significant Industrial Users are required to notify the Superintendent immediately of any changes at its facility affecting the potential for a Slug Discharge.
- E. The Superintendent will investigate violations through the collection and analysis of samples and other information in a manner designed to produce evidence that will be admissible in an enforcement proceeding or judicial action.

6.7 Reports from Unpermitted Users

All Users not required to obtain an individual wastewater discharge permit shall provide appropriate reports to the Superintendent as the Superintendent may require.

6.8 Notice of Violation/Repeat Sampling and Reporting

If sampling performed by a User indicates a violation, the User must notify the Superintendent within twenty-four (24) hours of becoming aware of the violation. The User shall also repeat the sampling and analysis and submit the results of the repeat analysis to the Superintendent within thirty (30) days after becoming aware of the violation. Resampling by the Industrial User is not required if the City performs sampling at the User's facility at least once a month, or if the City performs sampling at the User between the time when the initial sampling was conducted and the time when the User or the City receives the results of this sampling, or if the City has performed the sampling and analysis in lieu of the Industrial User.

6.9 Notification of the Discharge of Hazardous Waste

- A. Any User who commences the discharge of hazardous waste shall notify the POTW, the EPA Regional Waste Management Division Director, and State hazardous waste authorities, in writing, of any discharge into the POTW of a substance which, if otherwise disposed of, would be a hazardous waste under 40 CFR Part 261. Such notification must include the name of the hazardous waste as set forth in 40 CFR Part 261, the EPA hazardous waste number, and the type of discharge (continuous, batch, or other). If the User discharges more than one hundred (100) kilograms of such waste per calendar month to the POTW, the notification also shall contain the following information to the extent such information is known and readily available to the User: an identification of the hazardous constituents contained in the wastes, an estimation of the mass and concentration of such constituents in the wastestream discharged during that calendar month, and an estimation of the mass of constituents in the wastestream expected to be discharged during the following twelve (12) months. All notifications must take place no later than one hundred and eighty (180) days after the discharge commences. Any notification under this paragraph need be submitted only once for each hazardous waste discharged. However, notifications of changed conditions must be submitted under Section 6.5 of this ordinance. The notification requirement in this Section does not apply to pollutants already reported by Users subject to categorical Pretreatment Standards under the self-monitoring requirements of Sections 6.1, 6.3, and 6.4 of this ordinance.
- B. Dischargers are exempt from the requirements of paragraph A, above, during a calendar month in which they discharge no more than fifteen (15) kilograms of hazardous wastes, unless the wastes are acute hazardous wastes as specified in 40 CFR 261.30(d) and 261.33(e). Discharge of more than fifteen (15) kilograms of nonacute hazardous wastes in a calendar month, or of any quantity of acute hazardous wastes as specified in 40 CFR 261.30(d) and 261.33(e), requires a one-time notification. Subsequent months during which the User discharges more than such quantities of any hazardous waste do not require additional notification.
- C. In the case of any new regulations under section 3001 of RCRA identifying additional characteristics of hazardous waste or listing any additional substance as a hazardous waste, the User must notify the Superintendent, the EPA Regional Waste Management Waste Division Director, and State hazardous waste authorities of the discharge of such substance within ninety (90) days of the effective date of such regulations.

- D. In the case of any notification made under this Section, the User shall certify that it has a program in place to reduce the volume and toxicity of hazardous wastes generated to the degree it has determined to be economically practical.
- E. This provision does not create a right to discharge any substance not otherwise permitted to be discharged by this ordinance, a permit issued thereunder, or any applicable Federal or State law.

6.10 Analytical Requirements

All pollutant analyses, including sampling techniques, to be submitted as part of a wastewater discharge permit application or report shall be performed in accordance with the techniques prescribed in 40 CFR Part 136 and amendments thereto, unless otherwise specified in an applicable categorical Pretreatment Standard. If 40 CFR Part 136 does not contain sampling or analytical techniques for the pollutant in question, or where the EPA determines that the Part 136 sampling and analytical techniques are inappropriate for the pollutant in question, sampling and analyses shall be performed by using validated analytical methods or any other applicable sampling and analytical procedures, including procedures suggested by the Superintendent or other parties approved by EPA.

6.11 Sample Collection

Samples collected to satisfy reporting requirements must be based on data obtained through appropriate sampling and analysis performed during the period covered by the report, based on data that is representative of conditions occurring during the reporting period.

- A. Except as indicated in Section B and C below, the User must collect wastewater samples using 24-hour flow-proportional composite sampling techniques, unless time-proportional composite sampling or grab sampling is authorized by the Superintendent. Where time-proportional composite sampling or grab sampling is authorized by the City, the samples must be representative of the discharge. Using protocols (including appropriate preservation) specified in 40 CFR Part 136 and appropriate EPA guidance, multiple grab samples collected during a 24-hour period may be composited prior to the analysis as follows: for cyanide, total phenols, and sulfides the samples may be composited in the laboratory or in the field; for volatile organics and oil and grease, the samples may be composited in the laboratory. Composite samples for other parameters unaffected by the compositing procedures as documented in approved EPA methodologies may be authorized by the City, as appropriate. In addition, grab samples may be required to show compliance with Instantaneous Limits.
- B. Samples for oil and grease, temperature, pH, cyanide, total phenols, sulfides, and volatile organic compounds must be obtained using grab collection techniques.
- C. For sampling required in support of baseline monitoring and 90-day compliance reports required in Section 6.1 and 6.3, a minimum of four (4) grab samples must be used for pH, cyanide, total phenols, oil and grease, sulfide and volatile organic compounds for facilities for which historical sampling data do not exist; for facilities for which historical sampling data are available, the Superintendent may authorize a lower minimum. For the reports required by paragraphs Section 6.4 (40 CFR 403.12(e) and 403.12(h)), the Industrial User is required to collect the number of

grab samples necessary to assess and assure compliance by with applicable Pretreatment Standards and Requirements.

- D. All sampling shall be accompanied by a chain of custody form which includes the following sample collection information: Sample Identification, Sample Date, Sample Time, Sample Type, Number of Bottles, and Sample Collector Name. In addition, Sample Receipt information shall be included and shall consist of date, time, and person who received sample and any relevant preservation information.

6.12 Date of Receipt of Reports

Written reports will be deemed to have been submitted on the date postmarked. For reports, which are not mailed, postage prepaid, into a mail facility serviced by the United States Postal Service, the date of receipt of the report shall govern.

6.13 Recordkeeping

Users subject to the reporting requirements of this ordinance shall retain, and make available for inspection and copying, all records of information obtained pursuant to any monitoring activities required by this ordinance, any additional records of information obtained pursuant to monitoring activities undertaken by the User independent of such requirements, and documentation associated with Best Management Practices established under Section 2.4 D. Records shall include the date, exact place, method, and time of sampling, and the name of the person(s) taking the samples; the dates analyses were performed; who performed the analyses; the analytical techniques or methods used; and the results of such analyses. These records shall remain available for a period of at least five (5) years. This period shall be automatically extended for the duration of any litigation concerning the User or the City, or where the User has been specifically notified of a longer retention period by the Superintendent.

SECTION 7—COMPLIANCE MONITORING

7.1 Right of Entry: Inspection and Sampling

The Superintendent shall have the right to enter the premises of any User at reasonable times to determine whether the User is complying with all requirements of this ordinance and any individual wastewater discharge permit or order issued hereunder. Users shall allow the Superintendent ready access to all parts of the premises for the purposes of inspection, sampling, records examination and copying, and the performance of any additional duties.

- A. Where a User has security measures in force which require proper identification and clearance before entry into its premises, the User shall make necessary arrangements with its security guards so that, upon presentation of suitable identification, the Superintendent shall be permitted to enter without delay for the purposes of performing specific responsibilities.
- B. The Superintendent shall have the right to set up on the User's property, or require installation of, such devices as are necessary to conduct sampling and/or metering of the User's operations.
- C. The Superintendent may require the User to install monitoring equipment as necessary. The facility's sampling and monitoring equipment shall be maintained at all times in a safe and proper operating condition by the User at its own expense. All devices used to measure wastewater flow and quality shall be calibrated at least annually to ensure their accuracy.
- D. Any temporary or permanent obstruction to safe and easy access to the facility to be inspected and/or sampled shall be promptly removed by the User at the written or verbal request of the Superintendent and shall not be replaced. The costs of clearing such access shall be borne by the User.
- E. Unreasonable delays in allowing the Superintendent access to the User's premises shall be a violation of this ordinance.

7.2 Search Warrants

If the Superintendent has been refused access to a building, structure, or property, or any part thereof, and is able to demonstrate probable cause to believe that there may be a violation of this ordinance, or that there is a need to inspect and/or sample as part of a routine inspection and sampling program of the City designed to verify compliance with this ordinance or any permit or order issued hereunder, or to protect the overall public health, safety and welfare of the community, the Superintendent may seek issuance of a search warrant from the Johnson County Circuit Court of Franklin, Indiana.

SECTION 8—CONFIDENTIAL INFORMATION

Information and data on a User obtained from reports, surveys, wastewater discharge permit applications, individual wastewater discharge permits, and monitoring programs, and from the Superintendent's inspection and sampling activities, shall be available to the public without restriction, unless the User specifically requests, and is able to demonstrate to the satisfaction of the Superintendent, that the release of such information would divulge information, processes, or methods of production entitled to protection as trade secrets under applicable State law. Any such request must be asserted at the time of submission of the information or data. When requested and demonstrated by the User furnishing a report that such information should be held confidential, the portions of a report which might disclose trade secrets or secret processes shall not be made available for inspection by the public, but shall be made available immediately upon request to governmental agencies for uses related to the NPDES program or pretreatment program, and in enforcement proceedings involving the person furnishing the report. Wastewater constituents and characteristics and other effluent data, as defined at 40 CFR 2.302 shall not be recognized as confidential information and shall be available to the public without restriction.

SECTION 9—PUBLICATION OF USERS IN SIGNIFICANT NONCOMPLIANCE

Per 40 CFR 403.8(f)(2)(viii), the Superintendent shall publish annually, in the largest daily newspaper a newspaper of general circulation that provides meaningful public notice within the jurisdictions served by the POTW, a list of the Users which, at any time during the previous twelve (12) months, were in Significant Noncompliance with applicable Pretreatment Standards and Requirements. The term Significant Noncompliance shall be applicable to all Significant Industrial Users (or any other Industrial User that violates paragraphs (C), (D) or (H) of this Section) and shall mean:

- A. Chronic violations of wastewater discharge limits, defined here as those in which sixty-six percent (66%) or more of all the measurements taken for the same pollutant parameter taken during a six- (6-) month period exceed (by any magnitude) a numeric Pretreatment Standard or Requirement, including Instantaneous Limits as defined in Section 2;
- B. Technical Review Criteria (TRC) violations, defined here as those in which thirty-three percent (33%) or more of wastewater measurements taken for each pollutant parameter during a six- (6-) month period equals or exceeds the product of the numeric Pretreatment Standard or Requirement including Instantaneous Limits, as defined by Section 2 multiplied by the applicable criteria (1.4 for BOD, TSS, fats, oils and grease, and 1.2 for all other pollutants except pH);
- C. Any other violation of a Pretreatment Standard or Requirement as defined by Section 2 (Daily Maximum, long-term average, Instantaneous Limit, or narrative standard) that the Superintendent determines has caused, alone or in combination with other discharges, Interference or Pass Through, including endangering the health of POTW personnel or the general public;
- D. Any discharge of a pollutant that has caused imminent endangerment to the public or to the environment, or has resulted in the Superintendent's exercise of its emergency authority to halt or prevent such a discharge;
- E. Failure to meet, within ninety (90) days of the scheduled date, a compliance schedule milestone contained in an individual wastewater discharge permit or enforcement order for starting construction, completing construction, or attaining final compliance;
- F. Failure to provide within forty-five (45) days after the due date, any required reports, including baseline monitoring reports, reports on compliance with categorical Pretreatment Standard deadlines, periodic self-monitoring reports, and reports on compliance with compliance schedules;
- G. Failure to accurately report noncompliance; or
- H. Any other violation(s), which may include a violation of Best Management Practices, which the Superintendent determines will adversely affect the operation or implementation of the local pretreatment program.

SECTION 10—ADMINISTRATIVE ENFORCEMENT REMEDIES

10.1 Letter of Violation

When the Superintendent finds that a User has violated, or continues to violate, any provision of this ordinance, an individual wastewater discharge permit, or order issued hereunder, or any other Pretreatment Standard or Requirement, the Superintendent may serve upon that User a written Notice of Violation. Within five (5) working days of the receipt of such notice, an explanation of the violation and a plan for the satisfactory correction and prevention thereof, to include specific required actions, shall be submitted by the User to the Superintendent. Submission of such a plan in no way relieves the User of liability for any violations occurring before or after receipt of the Notice of Violation. Nothing in this Section shall limit the authority of the Superintendent to take any action, including emergency actions or any other enforcement action, without first issuing a Notice of Violation.

10.2 Consent Orders or Agreed Orders

The Superintendent may enter into Consent Orders, assurances of compliance, or other similar documents establishing an agreement with any User responsible for noncompliance. Such documents shall include specific action to be taken by the User to correct the noncompliance within a time period specified by the document. Such documents shall have the same force and effect as the orders issued pursuant to Sections 10.4 and 10.5 of this ordinance and shall be judicially enforceable.

10.3 Show Cause Hearing

The Superintendent may order a User which has violated, or continues to violate, any provision of this ordinance, an individual wastewater discharge permit, or order issued hereunder, or any other Pretreatment Standard or Requirement, to appear before the Superintendent and show cause why the proposed enforcement action should not be taken. Notice shall be served on the User specifying the time and place for the meeting, the proposed enforcement action, the reasons for such action, and a request that the User show cause why the proposed enforcement action should not be taken. The notice of the meeting shall be served personally or by registered or certified mail (return receipt requested) at least fifteen (15) days prior to the hearing. Such notice may be served on any Authorized Representative of the User as defined in Section 1.4 C and required by Section 4.6. A show cause hearing shall not be a bar against, or prerequisite for, taking any other action against the User.

10.4 Compliance Orders

When the Superintendent finds that a User has violated, or continues to violate, any provision of this ordinance, an individual wastewater discharge permit, or order issued hereunder, or any other Pretreatment Standard or Requirement, the Superintendent may issue an order to the User responsible for the discharge directing that the User come into compliance within a specified time. If the User does not come into compliance within the time provided, sewer service may be discontinued unless adequate treatment facilities, devices, or other related appurtenances are installed and properly operated. Compliance orders also may contain other requirements to address the noncompliance, including additional self-monitoring and management practices designed to minimize the amount of pollutants discharged to the sewer. A compliance order may not extend the deadline for compliance established for a Pretreatment Standard or Requirement, nor does a compliance order relieve the User of liability for any

violation, including any continuing violation. Issuance of a compliance order shall not be a bar against, or a prerequisite for, taking any other action against the User.

10.5 Cease and Desist Orders

When the Superintendent finds that a User has violated, or continues to violate, any provision of this ordinance, an individual wastewater discharge permit, or order issued hereunder, or any other Pretreatment Standard or Requirement, or that the User's past violations are likely to recur, the Superintendent may issue an order to the User directing it to cease and desist all such violations and directing the User to:

- A. Immediately comply with all requirements; and
- B. Take such appropriate remedial or preventive action as may be needed to properly address a continuing or threatened violation, including halting operations and/or terminating the discharge. Issuance of a cease and desist order shall not be a bar against, or a prerequisite for, taking any other action against the User.

10.6 Administrative Fines

- A. When the Superintendent finds that a User has violated, or continues to violate, any provision of this ordinance, an individual wastewater discharge permit, or order issued hereunder, or any other Pretreatment Standard or Requirement, the Superintendent may fine such User in an amount of not more than two thousand five hundred dollars (\$2,500) per day, per violation for a first violation nor more than seven thousand five hundred dollars (\$7,500) per day, per violation for subsequent violations. Such fines shall be assessed on a per-violation, per-day basis. In the case of monthly or other long-term average discharge limits, fines shall be assessed for each day during the period of violation.
- B. Users desiring to dispute such fines must file a written request for the Superintendent to reconsider the fine along with full payment of the fine amount within thirty (30) days of being notified of the fine. Where a request has merit, the Superintendent may convene a hearing on the matter. In the event the User's appeal is successful, the payment, together with any interest accruing thereto, shall be returned to the User. The Superintendent may add the costs of preparing administrative enforcement actions, such as notices and orders, to the fine.
- C. Issuance of an administrative fine shall not be a bar against, or a prerequisite for, taking any other action against the User.

10.7 Emergency Suspensions

The Superintendent may immediately suspend a User's discharge, after informal notice to the User, whenever such suspension is necessary to stop an actual or threatened discharge, which reasonably appears to present, or cause an imminent or substantial endangerment to the health or welfare of persons. The Superintendent may also immediately suspend a User's discharge, after notice and opportunity to respond, that threatens to interfere with the operation of the POTW, or which presents, or may present, an endangerment to the environment.

- A. Any User notified of a suspension of its discharge shall immediately stop or eliminate its contribution. In the event of a User's failure to immediately comply voluntarily with the suspension order, the Superintendent may take such steps as deemed necessary, including immediate severance of the sewer connection, to prevent or minimize damage to the POTW, its receiving stream, or endangerment to any individuals. The Superintendent may allow the User to recommence its discharge when the User has demonstrated to the satisfaction of the Superintendent that the period of endangerment has passed, unless the termination proceedings in Section 10.8 of this ordinance are initiated against the User.
- B. A User that is responsible, in whole or in part, for any discharge presenting imminent endangerment shall submit a detailed written statement, describing the causes of the harmful contribution and the measures taken to prevent any future occurrence, to the Superintendent prior to the date of any show cause or termination hearing under Sections 10.3 or 10.8 of this ordinance.

Nothing in this Section shall be interpreted as requiring a hearing prior to any Emergency Suspension under this Section.

10.8 Termination of Discharge

In addition to the provisions in Section 5.5 of this ordinance, any User who violates the following conditions is subject to discharge termination:

- A. Violation of individual wastewater discharge permit;
- B. Failure to accurately report the wastewater constituents and characteristics of its discharge;
- C. Failure to report significant changes in operations or wastewater volume, constituents, and characteristics prior to discharge;
- D. Refusal of reasonable access to the User's premises for the purpose of inspection, monitoring, or sampling; or
- E. Violation of the Pretreatment Standards in Section 2 of this ordinance.

Such User will be notified of the proposed termination of its discharge and be offered an opportunity to show cause under Section 10.3 of this ordinance why the proposed action should not be taken. Exercise of this option by the Superintendent shall not be a bar to, or a prerequisite for, taking any other action against the User.

SECTION 11—JUDICIAL ENFORCEMENT REMEDIES

11.1 Injunctive Relief

When the Superintendent finds that a User has violated, or continues to violate, any provision of this ordinance, an individual wastewater discharge permit, or order issued hereunder, or any other Pretreatment Standard or Requirement, the Superintendent may petition the Johnson County Circuit Court through the City's Attorney for the issuance of a temporary or permanent injunction, as appropriate, which restrains or compels the specific performance of the individual wastewater discharge permit, order, or other requirement imposed by this ordinance on activities of the User. The Superintendent may also seek such other action as is appropriate for legal and/or equitable relief, including a requirement for the User to conduct environmental remediation. A petition for injunctive relief shall not be a bar against, or a prerequisite for, taking any other action against a User.

11.2 Civil Penalties

- A. A User who has violated, or continues to violate, any provision of this ordinance, an individual wastewater discharge permit, or order issued hereunder, or any other Pretreatment Standard or Requirement shall be liable to the City for not more than two thousand five hundred dollars (\$2,500) per day, per violation for a first violation nor more than seven thousand five hundred dollars (\$7,500) per day, per violation for subsequent violations. In the case of a monthly or other long-term average discharge limit, penalties shall accrue for each day during the period of the violation.
- B. The Superintendent may recover reasonable attorneys' fees, court costs, and other expenses associated with enforcement activities, including sampling and monitoring expenses, and the cost of any actual damages incurred by the City.
- C. In determining the amount of civil liability, the Court shall take into account all relevant circumstances, including, but not limited to, the extent of harm caused by the violation, the magnitude and duration of the violation, any economic benefit gained through the User's violation, corrective actions by the User, the compliance history of the User, and any other factor as justice requires.
- D. Filing a suit for civil penalties shall not be a bar against, or a prerequisite for, taking any other action against a User.

11.3 Remedies Nonexclusive

The remedies provided for in this ordinance are not exclusive. The Superintendent may take any, all, or any combination of these actions against a noncompliant User. Enforcement of pretreatment violations will generally be in accordance with the City's Enforcement Response Plan (ERP). Per 40 CFR Section 403.8 (f)(1)(vi), the City has legal authority to enforce the ERP. However, the Superintendent may take other action against any User when the circumstances warrant. Further, the Superintendent is empowered to take more than one enforcement action against any noncompliant User.

SECTION 12—AFFIRMATIVE DEFENSES TO DISCHARGE VIOLATIONS

12.1 Upset

- A. For the purposes of this Section, upset means an exceptional incident in which there is unintentional and temporary noncompliance with categorical Pretreatment Standards because of factors beyond the reasonable control of the User. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- B. An upset shall constitute an affirmative defense to an action brought for noncompliance with categorical Pretreatment Standards if the requirements of paragraph (C), below, are met.
- C. A User who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and the User can identify the cause(s) of the upset;
 - (2) The facility was at the time being operated in a prudent and workman-like manner and in compliance with applicable operation and maintenance procedures; and
 - (3) The User has submitted the following information to the Superintendent within twenty-four (24) hours of becoming aware of the upset if this information is provided orally, a written submission must be provided within five (5) days:
 - (a) A description of the indirect discharge and cause of noncompliance;
 - (b) The period of noncompliance, including exact dates and times or, if not corrected, the anticipated time the noncompliance is expected to continue; and
 - (c) Steps being taken and/or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
- D. In any enforcement proceeding, the User seeking to establish the occurrence of an upset shall have the burden of proof.
- E. Users shall have the opportunity for a judicial determination on any claim of upset only in an enforcement action brought for noncompliance with categorical Pretreatment Standards.
- F. Users shall control production of all discharges to the extent necessary to maintain compliance with categorical Pretreatment Standards upon reduction, loss, or failure of its treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

12.2 Prohibited Discharge Standards

A User shall have an affirmative defense to an enforcement action brought against it for noncompliance with the general prohibitions in Section 2.1(A) of this ordinance or the specific prohibitions in Sections 2.1(B)(1) through (17) of this ordinance if it can prove that it did not know, or have reason to know, that its discharge, alone or in conjunction with discharges from other sources, would cause Pass Through or Interference and that either:

- A. A Local Limit exists for each pollutant discharged and the User was in compliance with each limit directly prior to, and during, the Pass Through or Interference; or
- B. No Local Limit exists, but the discharge did not change substantially in nature or constituents from the User's prior discharge when the City was regularly in compliance with its NPDES permit, and in the case of Interference, was in compliance with applicable sludge use or disposal requirements.

12.3 Bypass

- A. For the purposes of this Section,
 - (1) "Bypass" means the intentional diversion of wastestreams from any portion of a User's treatment facility.
 - (2) "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- B. A User may allow any bypass to occur which does not cause Pretreatment Standards or Requirements to be violated, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provision of paragraphs (C) and (D) of this Section.
- C. Bypass Notifications
 - (1) If a User knows in advance of the need for a bypass, it shall submit prior notice to the Superintendent, at least ten (10) days before the date of the bypass, if possible.
 - (2) A User shall submit oral notice to the Superintendent of an unanticipated bypass that exceeds applicable Pretreatment Standards within twenty-four (24) hours from the time it becomes aware of the bypass. A written submission shall also be provided within five (5) days of the time the User becomes aware of the bypass. The written submission shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times, and, if the bypass has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass. The Superintendent may waive the written report on a case-by-case basis if the oral report has been received within twenty-four (24) hours.

D. Bypass

- (1) Bypass is prohibited, and the Superintendent may take an enforcement action against a User for a bypass, unless
 - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (c) The User submitted notices as required under paragraph (C) of this section.
- (2) The Superintendent may approve an anticipated bypass, after considering its adverse effects, if the Superintendent determines that it will meet the three conditions listed in paragraph (D)(1) of this Section.

SECTION 13—MISCELLANEOUS PROVISIONS

13.1 Pretreatment Charges and Fees

The City may adopt reasonable fees for reimbursement of costs of setting up and operating the City's Pretreatment Program, which may include:

- A. Fees for wastewater discharge permit applications including the cost of processing such applications;
- B. Fees for monitoring, inspection, and surveillance procedures including the cost of collection and analyzing a User's discharge, and reviewing monitoring reports and certification statements submitted by Users;
- C. Fees for reviewing and responding to accidental discharge procedures and construction;
- D. Fees for filing appeals;
- E. Fees to recover administrative and legal costs (not included in Section 13.1 B) associated with the enforcement activity taken by the Superintendent to address IU noncompliance; and
- F. Other fees as the City may deem necessary to carry out the requirements contained herein. These fees relate solely to the matters covered by this ordinance and are separate from all other fees, fines, and penalties chargeable by the City.

13.2 Severability

If any provision of this ordinance is invalidated by any court of competent jurisdiction, the remaining provisions shall not be affected and shall continue in full force and effect.

SECTION 14—EFFECTIVE DATE

This ordinance shall be in full force and effect immediately following its passage, approval, and publication, as provided by law.


The foregoing ordinance was passed and adopted by the City Council and Board of Works for the Civil City of Franklin, Indiana at a regular meeting held on the ^{17th} day of April, 20 23.

Steve Barnett, Mayor




City Council:

Jennifer Price, Councilor




Josh Prine, Councilor




Anne McGuinness, Councilor




Kenneth Austin, Councilor



Irene Nalley, Councilor



Shawn Taylor, Councilor



Bob Heuchan, Councilor



ATTEST:

Jayne W. Rhoades, Clerk-Treasurer

